

Water Quality Report – 2010

Lincoln Water Works

What is the source of my drinking water?

1) Lincoln Water Treatment Plant

- a) Loon Pond #005 – A pond, located on White Mountain National Forest land, that feeds water to Little Loon Pond and then into a small reservoir. The water from this surface water source is classified as Class A water, which is treated at the Water Treatment Plant.
- b) East Branch of the Pemigewasset River #006 – A river, located within the White Mountain National Forest, with many tributaries that drain the surrounding Lincoln Woods and provides sufficient water to the Town’s intake facility. The water from this surface water source is classified as Class B water, which is also treated at the Water Treatment Plant.

[Note: Class A water is a better quality raw water than Class B water because it contains less bacteria. Because water from both Loon Pond and the East Branch of the Pemigewasset River are treated through the Water Treatment Plant, all bacteria is removed from both sources. Therefore, the differences between Class A water and Class B water is not a matter of concern.]

2) Cold Springs Well Group #004

A ground water source, located on Route 3, which is used mainly during the high demand periods. This water originates from the Main Branch of the Pemigewasset River. Water from wells must be chlorinated to destroy any bacteria that may be present and pH levels are adjusted to protect against corrosion.

How can I get involved? If you should have any questions or concerns, please call David Beaudin at the Lincoln Water Department Monday to Friday, from 7:00am to 3:30 pm, at (603)745-9306.

Why are contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US Environmental Protection Agency’s Safe Drinking Water Hotline (1-800-426-4791).

Violations and Other information:

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Definitions:

MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. They are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

MRDLG: Maximum residual disinfectant level goal or the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG’s do not reflect the benefits of the use of disinfectants to control microbial contaminants(for water systems that use chlorine).

MRDL: Maximum Residual Disinfectant Level or the highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants (for water systems that use chlorine)..

Abbreviations:

ppm: parts per million **ppb:** parts per billion **ppt:** parts per trillion **ppq:** parts per quadrillion **pCi/L:** pico curies per liter **NTU:** Nephelometric Turbidity Unit
NA – Not applicable **nd:** not detectable at testing limits **AL:** Action Level **TT:** Treatment Technique

Sample Dates: The results for detected contaminants listed below are from the most recent monitoring done in compliance with regulations ending with the year 2009. Results prior to 2009 will include the date the sample was taken. The State of New Hampshire allows water systems to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Thus some of the data present, though representative, may be more than one year old.

Turbidity: is a measure of the cloudiness of the water. It is monitored by surface water systems because it is a good indicator of water quality and thus helps measure the effectiveness of the treatment process. High turbidity can hinder the effectiveness of disinfectants.

DETECTED WATER QUALITY RESULTS

| Contaminant (Units) | Level Detected | MCL | MCLG | Violation YES/NO | Likely Source of Contamination | Health Effects of Contaminant |
|-------------------------------------|----------------------------------|------------|-------------|-------------------------|--|---|
| Microbiological Contaminants | | | | | | |
| Total Organic Carbon (ppm) | RAA Average 1.3 Range 1.0-1.5 | TT | N/A | NO | Naturally present in the Environment | Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver, or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer. |
| Turbidity (NTU) | Average .14 Range .07-.28 | TT | N/A | NO | Soil runoff | Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches. |
| Inorganic Contaminants | | | | | | |
| Copper (ppm) | Average .011 Range .003-.032 | AL=1.3 | 1.3 | NO | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives | Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson’s Disease should consult their personal doctor. |
| Fluoride (ppm) | .5 | 4 | 4 | NO | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and | Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children’s teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums. |

| | | | | | | |
|---|--|----------|-----------|----|--|---|
| | | | | | aluminum factories | |
| Lead (ppb) | Number of samples above the AL of 15 ppb were: None Range: <.001-.002 | AL=15 | 0 | NO | Corrosion of household plumbing systems, erosion of natural deposits | (15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). (above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. |
| Volatile Organic Contaminants | | | | | | |
| Chlorine (ppm) | Average .525 Range .47-.525 | MRDL = 4 | MRDLG = 4 | NO | Water additive used to control microbes | Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort. |
| Haloacetic Acids (ppb) | 8/4/09 .081 12/16/09 .033 Average .057 | 60 | N/A | NO | By-product of drinking water disinfection | Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. |
| TTHM (Bromodichloromethane Bromoform Dibromomethane Chloroform) (ppb) | 8/4/09 .069 12/16/09 .030 Average .495 | 80 | N/A | NO | By-product of drinking water chlorination | Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. |

Description of Drinking Water Contaminants:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The United States Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Radon: Radon is a radioactive gas that you can't see, taste or smell. It can move up through the ground and into a home through cracks and holes in the foundation. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. It is a known human carcinogen. Breathing radon can lead to lung cancer. Drinking water containing radon may cause an increased risk of stomach cancer. Presently the EPA is reviewing a standard for radon in water.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water, but can not control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Assessment Summary:

The NH Department of Environmental Services has prepared a Source Water Assessment Report for the source(s) serving this community water system, assessing the sources' vulnerability to contamination. The results of the assessment, prepared on (date(s)), are as follows:

(First source name and/or description), received (number) high susceptibility ratings, (number) medium susceptibility ratings, and (number) low susceptibility ratings.
(Second source name and/or description) received (number) high susceptibility ratings, (number) medium susceptibility ratings, and (number) low susceptibility ratings.
(Third source name and/or description), received (number) high susceptibility ratings, (number) medium susceptibility ratings, and (number) low susceptibility ratings.

The complete Assessment Report is available for review at (water system office or other location). For more information call (water system's contact and telephone number) or visit NH Department of Environmental Services Drinking Water & Groundwater Bureau web site at www.des.nh.gov/dwgb

Unregulated Contaminants: