

IMPORTANT NOTICE ABOUT YOUR DRINKING WATER

Monitoring & Reporting Requirements Not Met

Public Water System Name: Lincoln Water Works PWS ID: 1351010

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted below, we did not "monitor or test" or "did not complete all monitoring or testing" for the listed contaminants, and therefore cannot be sure of the quality of your drinking water at that time.

Contaminant(s) (What we were supposed to sample for)	Compliance Period (Month or quarter and year we were supposed to sample)	Date sample was or will be collected (If a make-up sample is required)
Disinfection By-Product	Quarter #1 2023	March 2023 And monthly thereafter from water treatment plant.
Precursors – T.O.C.* and Alkalinity	Month of February	
*T.O.C. Total Organic Compounds		

What should I do?

There is nothing you need to do at this time. Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Steps being taken to correct the situation: Remaining on regular monthly sampling

Expected Resolution Date: After 2nd Quarter

Contact Name: Dave Beaudin Company: Town of Lincoln

Address: 148 Main Street, Lincoln, NH 03251 Telephone Number: (603) 745-9306

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.